

# Power*Scout* 24

## Calibration Stability and Traceability Statement

April, 2014



The robust, inherently stable electrical design makes the **Power*Scout* 24** highly resistant to aging and drift phenomena that cause calibration errors. Our experience with this device indicates that the calibration of the **Power*Scout* 24** remains within the manufacturer's specifications for a minimum of three years, and in most cases factory recalibration is never required.

The calibration of each **Power*Scout* 24** is traceable to the National Institute of Standards and Technology (NIST) using these reference instruments.

- Hewlett Packard 34401A Multimeter
- Agilent 34411A Multimeter